


**Silver Falls School District - Evergreen School**

**Lead Testing Results Summary June 2019**



Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Page 1 of 1

**NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on our information.**

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter (or ppm) Action Level of 0.015	Lead Test Results, ppb Action Level of 15
6/25/2019	20190625-063	Kitchen sink	0.0073	7.3
6/25/2019	20190625-064	G-1 sink	0.0022	2.2
6/25/2019	20190625-065	B-1 sink	ND @ 0.001	ND @ 1
6/25/2019	20190625-066	Cafeteria DF	0.0019	1.9
6/25/2019	20190625-067	7/8 Classroom sink	0.0088	8.8
6/25/2019	20190625-068	5/6 Classroom sink	0.0023	2.3
6/25/2019	20190625-069	K-2 Classroom sink	0.0026	2.6
6/25/2019	20190625-070	Exterior DF	0.0019	1.9

ND means No Detection at stated value. \*\*\* Sample Size 250 mL Containers

# WATERLAB CORP.

2603 12<sup>th</sup> Street SE  
Salem, OR 97302

Date/Tm  
Correct Container  
Correct Volume  
Hold Time

06252019 13:13

B/N  
B/N  
B/N

Rec'd By: *[Signature]*

Relinquished  
By: *[Signature]*

Signature  
Printed Name  
*Beland*

SEND RESULTS TO:

Co. Name: Silver Falls School District  
Address: 612 Schladter Street  
City: Silver Falls State: OR  
Zip Code: 97381 Phone: 503-873-5303

SEND BILL TO:

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_  
Zip Code: \_\_\_\_\_ Phone: \_\_\_\_\_

PROJECT: Lead \_\_\_\_\_ Evergreen School

COLLECTED BY: Lorin Stanley

EST	DATE	TIME	SOURCE	AB #
Pb, [redacted]	6.25.19	9:04am	Kitchen Sink	20190625-603
Pb, [redacted]	6.25.19	9:04am	G-1 Sink	20190625-004
Pb, [redacted]	6.25.19	9:04am	B-1 Sink	20190625-005
Pb, [redacted]	6.25.19	9:03am	Cafeteria D.F.	20190625-006
Pb, [redacted]	6.25.19	8:54am	7/8 classroom Sink	20190625-007

EST	DATE	TIME	SOURCE	AB #
<del>Pb, [redacted]</del>	<del>6.25.19</del>	<del>Out of Service</del>	<del>7/8 Classroom Sink</del>	<del>20190625</del>
<del>Pb, [redacted]</del>	<del>6.25.19</del>	<del>8:53</del>	<del>5/6 Classroom Sink</del>	<del>20190625-008</del>
<del>Pb, [redacted]</del>	<del>6.25.19</del>	<del>Out of Service</del>	<del>E. Foyer D.F.</del>	<del>20190625</del>
<del>Pb, [redacted]</del>	<del>6.25.19</del>	<del>9:52am</del>	<del>K-2 Classroom Sink</del>	<del>20190625-009</del>
<del>Pb, [redacted]</del>	<del>6.25.19</del>	<del>Not a valid source</del>	<del>Hallway D.F.</del>	<del>20190625</del>

## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0901  
By: Lorin  
Lab #: 20190625-063  
Location: kitchen sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0073		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"


\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0904  
By: Lorin  
Lab #: 20190625-064  
Location: G-1 sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0022		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0904  
By: Lorin  
Lab #: 20190625-065  
Location: B-1 sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead	Schools/Bldgs	SM3113 B	A	ND	0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0903  
By: Lorin  
Lab #: 20190625-066  
Location: cafeteria DF

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0019		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0854  
By: Lorin  
Lab #: 20190625-067  
Location: 7/8 classroom sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0088		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL  
SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed  
EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA  
MRL-"Method Reporting Limit"

\* Accreditation  
A- Waterlab Corporation, ORELAP 100039  
The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0853  
By: Lorin  
Lab #: 20190625-068  
Location: 5/6 classroom sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0023		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_





## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0852  
By: Lorin  
Lab #: 20190625-069  
Location: K-2 classroom sink

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0026		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_

# WATERLAB CORP.

2603 12<sup>th</sup> Street SE  
Salem, OR 97302

Date/Tri: 06/25/09 13:18  
Correct Container: R1N  
Correct Volume: R1N  
Hold Time: Y1N

Rec'd By: *[Signature]*

Relinquished  
Signature: *[Signature]*  
Printed Name: Belando

SEND RESULTS TO:

Co. Name: Silver Falls School District  
Address: 612 Schlador Street  
City: Silverton State: OR  
Zip Code: 97381 Phone: 503-873-5303

SEND BILL TO:

Name: *[Signature]*  
Address: *[Signature]*  
City: *[Signature]* State: *[Signature]*  
Zip Code: \_\_\_\_\_ Phone: \_\_\_\_\_

PROJECT: Lead *[Redacted]* Evergreen School

COLLECTED BY: Kevin Stanley

EST	DATE	TIME	SOURCE	AB #	Pb	Pb	Pb	Pb
	6-25-19	8:59 am	Handwritten D.I. (B)	20190625070				

EST	DATE	TIME	SOURCE	AB #	Pb	Pb	Pb	Pb

## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

7/17/2019

SILFALSD/EVE

PO#: Evergreen

### Collection Information

Date: 6/25/2019  
Time: 0859  
By: Lorin  
Lab #: 20190625-070  
Location: exterior DF B

### Lab Receipt Information

6/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0019		0.001	mg/l	0.015	7/9/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_


**Silver Falls School District – Pratum School**

**Lead Testing Results Summary June 2019**

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Page 1 of 1



**NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on our information.**

<b>Date Collected</b>	<b>Lab #</b>	<b>Sample Site</b>	<b>Lead Test Results, mg/liter (or ppm) Action Level of 0.015</b>	<b>Lead Test Results, ppb Action Level of 15</b>
6/25/2019	20190625-134	S Hallway DR	0.0019	1.9
6/25/2019	20190625-135	Middle Classroom sink	ND @ 0.001	ND @ 1
6/25/2019	20190625-136	Middle Classroom bubbler	ND @ 0.001	ND @ 1
6/25/2019	20190625-137	E Classroom RR sink	0.0084	8.4
6/25/2019	20190625-138	E Classroom bubbler	0.0094	9.4
6/25/2019	20190625-139	E Classroom sink	0.0118	11.8
6/25/2019	20190625-140	Drinking Fountain A	0.0068	6.8
6/25/2019	20190625-141	Kitchen sink	ND @ 0.001	ND @ 1
6/25/2019	20190625-142	G-1 sink	0.0033	3.3
6/25/2019	20190625-143	B-1 sink	ND @ 0.001	ND @ 1

ND means No Detection at stated value. \*\*\* Sample Size 250 mL Containers

# WATERLAB CORP.

2603 12<sup>th</sup> Street SE  
Salem, OR 97302

Date/Time

06/25/2019 4:13:13

Correct Container  
Correct Volume  
Hold Time

11 N  
11 N  
11 N

Rec'd By:

*W*

Relinquished  
By:

Signature

Printed Name

*W. Bellman*  
Bellman, W. Bellman

SEND RESULTS TO:

Co. Name: Silver Falls School District  
Address: 612 Schlador Street  
City: Silverton State: OR  
Zip Code: 97381 Phone: 503-873-5303

SEND BILL TO:

Name: \_\_\_\_\_  
Address: \_\_\_\_\_  
City: \_\_\_\_\_ State: \_\_\_\_\_  
Zip Code: \_\_\_\_\_ Phone: \_\_\_\_\_

PROJECT: Lead Pratum School

COLLECTED BY: Lorin Stanley

TEST	DATE	TIME	SOURCE	AB #
Pb	6-25-19	8:02am	S Hallway D.F	20190625-0134
Pb	6-25-19	8:03am	Middle Classroom Sink	20190625-135
Pb	6-25-19	8:03am	Middle Classroom Rubber	20190625-0136
Pb	6-25-19	8:07am	E. Classroom R.R. Sink	20190625-137
Pb	6-25-19	8:06am	E. Classroom Rubber	20190625-138

TEST	DATE	TIME	SOURCE	AB #
Pb	6-25-19	8:08am	E. Classroom Sink	20190625-139
Pb	6-25-19	8:10am	Drinking Fountain	20190625-140
Pb	6-25-19	8:12am	Kitchen Sink	20190625-141
Pb	6-25-19	8:13am	G-1 Sink	20190625-142
Pb	6-25-19	8:13am	B-1 Sink	20190625-143

## TEST REPORT

2603 - 12th Street, SE  
Salem, OR 97302  
Voice: (503) 363-0473  
FAX: (503) 363-8900

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0802  
By: Lorin  
Lab #: 20190625-134  
Location: S hallway DF

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0019		0.001	mg/l	0.015	07/16/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0803  
By: Lorin  
Lab #: 20190625-135  
Location: middle classroom sink

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0803  
By: Lorin  
Lab #: 20190625-136  
Location: middle classroom bubbler

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_





## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0807  
By: Lorin  
Lab #: 20190625-137  
Location: E classroom RR sink

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0084		0.001	mg/l	0.015	07/16/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0806  
By: Lorin  
Lab #: 20190625-138  
Location: E classroom bubbler

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0094		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

**TO: Silver Falls School District 4J / Acct. Payable**  
**612 Schlador St**  
**Silverton, OR 97381**

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0808  
By: Lorin  
Lab #: 20190625-139  
Location: E classroom sink

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0118		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0810  
By: Lorin  
Lab #: 20190625-140  
Location: drinking fountain A

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date	Time
Lead Schools/Bldgs	SM3113 B	A	0.0068		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM-"Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA-"Methods for Chemical Analysis for Water and Wastes", USEPA

MRL-"Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0813  
By: Lorin  
Lab #: 20190625-142  
Location: G-1 sink

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA	Analysis	
							Limit	Date Time	Tech
Lead Schools/Bldgs	SM3113 B	A	0.0033		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_



## TEST REPORT

TO: Silver Falls School District 4J / Acct. Payable  
612 Schlador St  
Silverton, OR 97381

07/17/2019

SILFALSD/PRA

PO#: Pratum

### Collection Information

Date: 06/25/2019  
Time: 0813  
By: Lorin  
Lab #: 20190625-143  
Location: B-1 sink

### Lab Receipt Information

06/25/2019  
1313  
MH

### Case Narrative

The analyses were performed according to the guidelines in the WATERLAB Corp Quality Assurance Program. This report contains analytical results for the sample(s) as received by the laboratory.

WATERLAB Corp certifies that this report is in compliance with the requirements of NELAC. No unusual difficulties were experienced during analysis of this batch except as noted below or qualified with data flags on the reports.

Analyte	Method	Acc*	Results	Qual	MRL	Units	EPA Limit	Analysis	
								Date	Time
Lead Schools/Bldgs	SM3113 B	A	ND		0.001	mg/l	0.015	07/09/2019	BEM

ND- No Detection at @ MRL

SM- "Standard Methods for the Examination of Water & Wastewater", 19th ed

EPA- "Methods for Chemical Analysis for Water and Wastes", USEPA

MRL- "Method Reporting Limit"

\* Accreditation

A- Waterlab Corporation, ORELAP 100039

The results relate only to the parameters tested or to the sample as received by the laboratory.

This report shall not be reproduced except in full, without the written approval of Waterlab Corporation.

Approved by: \_\_\_\_\_