


Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008



Silver Falls School District 4J

Mark Twain School

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter**
6/17/16	20160617-18	MT Short Hallway Fountain	0.0010	0.020
6/17/16	20160617-19	MT Kitchen	0.0012	0.020
6/17/16	20160617-20	MT Stage	ND @ 0.001	0.020
6/17/16	20160617-21	MT Girls Locker Rm	0.0020	0.020
6/17/16	20160617-22	MT Rm 1	0.0104	0.020
6/17/16	20160617-23	MT Rm 5	0.0032	0.020
6/17/16	20160617-24	MT Rm 7	0.0046	0.020
6/17/16	20160617-25	MT Rm 11	0.0058	0.020
6/17/16	20160617-26	MT Rm 13	0.1728	0.020
6/17/16	20160617-27	MT Long Hallway Fountain	0.0046	0.020
6/17/16	20160617-28	MT Back of Media Rm Library	0.0044	0.020
6/17/16	20160617-29	MT Rm 8	ND @ 0.001	0.020
6/17/16	20160617-30	MT Rm 10	0.0068	0.020
6/17/16	20160617-31	MT Rm 12	0.0110	0.020
6/17/16	20160617-32	MT Rm 16	0.0041	0.020
6/17/16	20160617-33	MT Rm 14	0.0117	0.020

ND means No Detection at level specified.

\*\* 250 ml sample Action Level