

**Professional  
Laboratory  
Services**

13035 SW Pacific Hwy  
Tigard, OR 97223  
Tel.: (503) 639-9311 Fax: (503) 684-1588

**ANALYSIS REPORT**

ORELAP Accredited Lab#: OR-100013

Reported: 11/07/2016  
Received: 10/26/2016  
Sampled By:  
Work Order: 6300016

**C  
L  
I  
E  
N  
T**  
**Scotts Mills, City of**  
Attn: Mark Stoddard  
PO Box 220  
Scotts Mills OR, 97375  
Phone: (503) 580-0753

**Project:**  
Project # : N/A  
Sample Type :


Sampling Location: Scotts Mills School

**Lab Number**

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
<b>6300016-01</b>	<b>Sample Name:</b> Scotts Mills School Rm 2 <b>Sampled:</b> 10/26/16 11:45 <b>Sample Composition:</b> Treated Distribution Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43
<b>6300016-02</b>	<b>Sample Name:</b> Scotts Mills School Office Bathroom <b>Sampled:</b> 10/26/16 11:47 <b>Sample Composition:</b> Treated Distribution Single						<b>Matrix:</b> Drinking Water
+Lead	1030	EPA 200.9	ND	ppb	2.0	20 ppb	11/04/16 16:43

**ND** = None detected at the MRL    **MRL** = Minimum Reporting Limit    **MCL** = Maximum Contamination Limit  
†All procedures for this analysis are in accordance with NELAP standards.

\* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:   
Adriana Gonzalez-Gray  
Laboratory Director