


Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008



Silver Falls School District 4J

Scotts Mills School

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter**
6/17/16	20160617-59	SM Rm 1	0.0010	0.020
6/17/16	20160617-60	SM Rm 2	0.0032	0.020
6/17/16	20160617-61	SM Rm 3	0.0046	0.020
6/17/16	20160617-62	SM Rm 4	0.0038	0.020
6/17/16	20160617-63	SM Rm 5	0.0026	0.020
6/17/16	20160617-64	SM Rm 6	0.0043	0.020
6/17/16	20160617-65	SM Rm 9	0.0093	0.020
6/17/16	20160617-66	SM Rm 10	0.0098	0.020
6/17/16	20160617-67	SM Rm 11	0.0012	0.020
6/17/16	20160617-68	SM Rm 12	0.0020	

ND means No Detection at level specified.

** 250 ml sample Action Level