

Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008



Silver Falls School District 4J

Robert Frost School

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter**
6/17/16	20160617-34	RF 205	ND @ 0.001	0.020
6/17/16	20160617-35	RF 206	0.0010	0.020
6/17/16	20160617-36	RF 301	ND @ 0.001	0.020
6/17/16	20160617-37	RF 302	0.0010	0.020
6/17/16	20160617-38	RF 303	ND @ 0.001	0.020
6/17/16	20160617-39	RF 304	ND @ 0.001	0.020
6/17/16	20160617-40	RF 305	0.0011	0.020
6/17/16	20160617-41	RF 306	0.0010	0.020
6/17/16	20160617-42	RF 400	ND @ 0.001	0.020
6/17/16	20160617-43	RF 401	0.0025	0.020
6/17/16	20160617-44	RF 101	ND @ 0.001	0.020
6/17/16	20160617-45	RF 102	ND @ 0.001	0.020
6/17/16	20160617-46	RF 103	ND @ 0.001	0.020
6/17/16	20160617-47	RF 104	ND @ 0.001	0.020
6/17/16	20160617-48	RF 105	ND @ 0.001	0.020
6/17/16	20160617-49	RF 106	ND @ 0.001	0.020
6/17/16	20160617-50	RF 201	ND @ 0.001	0.020
6/17/16	20160617-51	RF 202	ND @ 0.001	0.020
6/17/16	20160617-52	RF 203	ND @ 0.001	0.020
6/17/16	20160617-53	RF 204	ND @ 0.001	0.020
6/17/16	20160617-54	RF Kitchen #1	0.0089	0.020
6/17/16	20160617-55	RF Kitchen #2	0.0029	0.020
6/17/16	20160617-56	RF Kitchen #3	0.0062	0.020
6/17/16	20160617-57	RF Hallway by Gym	0.0018	0.020
6/17/16	20160617-58	RF Staff Room	0.0020	0.020

ND means No Detection at level specified.

\*\* 250 ml sample Action Level

Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008



Silver Falls School District 4J

Scotts Mills School

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter**
6/17/16	20160617-59	SM Rm 1	0.0010	0.020
6/17/16	20160617-60	SM Rm 2	0.0032	0.020
6/17/16	20160617-61	SM Rm 3	0.0046	0.020
6/17/16	20160617-62	SM Rm 4	0.0038	0.020
6/17/16	20160617-63	SM Rm 5	0.0026	0.020
6/17/16	20160617-64	SM Rm 6	0.0043	0.020
6/17/16	20160617-65	SM Rm 9	0.0093	0.020
6/17/16	20160617-66	SM Rm 10	0.0098	0.020
6/17/16	20160617-67	SM Rm 11	0.0012	0.020
6/17/16	20160617-68	SM Rm 12	0.0020	

ND means No Detection at level specified.

\*\* 250 ml sample Action Level

Lead Testing Results Summary

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008



Silver Falls School District 4J

Mark Twain School

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter	Action Level, mg/liter**
6/17/16	20160617-18	MT Short Hallway Fountain	0.0010	0.020
6/17/16	20160617-19	MT Kitchen	0.0012	0.020
6/17/16	20160617-20	MT Stage	ND @ 0.001	0.020
6/17/16	20160617-21	MT Girls Locker Rm	0.0020	0.020
6/17/16	20160617-22	MT Rm 1	0.0104	0.020
6/17/16	20160617-23	MT Rm 5	0.0032	0.020
6/17/16	20160617-24	MT Rm 7	0.0046	0.020
6/17/16	20160617-25	MT Rm 11	0.0058	0.020
6/17/16	20160617-26	MT Rm 13	0.1728	0.020
6/17/16	20160617-27	MT Long Hallway Fountain	0.0046	0.020
6/17/16	20160617-28	MT Back of Media Rm Library	0.0044	0.020
6/17/16	20160617-29	MT Rm 8	ND @ 0.001	0.020
6/17/16	20160617-30	MT Rm 10	0.0068	0.020
6/17/16	20160617-31	MT Rm 12	0.0110	0.020
6/17/16	20160617-32	MT Rm 16	0.0041	0.020
6/17/16	20160617-33	MT Rm 14	0.0117	0.020

ND means No Detection at level specified.

\*\* 250 ml sample Action Level