


Silver Falls School District – Silverton High School

Lead Testing Results Summary 11/07/2016

Prepared by Beth Myers, Lab Director

Waterlab Corp, Oregon Accredited Laboratory ORELAP 100039, EPA #0008

Page 1 of 3



NOTE: The Lead Test Results are provided here in two (2) different units so you can choose which one you want to use on our information.

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter (or ppm) Action Level of 0.020	Lead Test Results, ppb Action Level of 20
10/20/2016	20161020-13	SHS C131 Sector C sink (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-14	SHS C131 Sector C Sink (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-15	SHS Frosty Fox Sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-16	SHS Student Store Sink	0.0019	1.9
10/20/2016	20161020-17	SHS Room between C132 & 133 sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-18	SHS C134 Sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-19	SHS Kitchen sink (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-20	SHS Kitchen sink (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-21	SHS Kitchen sink (3)	ND @ 0.001	ND @ 1
10/20/2016	20161020-22	SHS Kitchen sink (4)	ND @ 0.001	ND @ 1
10/20/2016	20161020-23	SHS Sector B B129 sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-24	SHS Sector B B128 sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-25	SHS Sector B hall fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-26	SHS Sector B Hall fountain (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-27	SHS Admin office staff kitchen sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-28	SHS Admin office Sick room sink	0.0014	1.4
10/20/2016	20161020-29	SHS A Sector A116 sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-30	SHS A Sector Hall fountain (3)	ND @ 0.001	ND @ 1
10/20/2016	20161020-31	SHS A Sector Hall fountain (4)	ND @ 0.001	ND @ 1
10/20/2016	20161020-32	SHS A sector A111 Fountain (A)	0.0023	2.3
10/20/2016	20161020-33	SHS A Sector A111 Fountain (B)	0.0021	2.1
10/20/2016	20161020-34	SHS Counseling Area Kitchen sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-35	SHS Counseling Area Hall Fountains	0.0014	1.4
10/20/2016	20161020-36	SHS Staff Rm sink	0.0014	1.4

ND means No Detection at stated value. *** Sample Size 250 mL Containers

Silver Falls School District – Silverton High School

Lead Testing Results Summary 11/07/2016

Page 2 of 3

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter (or ppm) Action Level of 0.020	Lead Test Results, ppb Action Level of 20
10/20/2016	20161020-61	SHS CTE F 102 Hall fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-62	SHS CTE F102 hall fountain (2)	0.0013	1.3
10/20/2016	20161020-63	SHS CTE F111 Hall fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-64	SHS CTE F111 Hall fountain (2)	0.0011	1.1
10/20/2016	20161020-65	SHS CTE F121 Hall fountain (2)	0.0028	2.8
10/20/2016	20161020-66	SHS CTE F121 Hall fountain (1)	0.0011	1.1
10/20/2016	20161020-67	SHS B Sector B202 sink (5)	ND @ 0.001	ND @ 1
10/20/2016	20161020-68	SHS B Sector B201 sink (6)	ND @ 0.001	ND @ 1
10/20/2016	20161020-69	SHS B Sector B200 sink (8)	ND @ 0.001	ND @ 1
10/20/2016	20161020-70	SHS B Sector Hallway fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-71	SHS B Sector Hallway fountain (2)	0.0010	1.0
10/20/2016	20161020-72	SHS B Sector B207 sink (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-73	SHS A Sector A202 (2)	0.0030	3.0
10/20/2016	20161020-74	SHS A Sector A203 sink (4)	0.0048	4.8
10/20/2016	20161020-75	SHS A Sector A204 Sink (1)	0.0042	4.2
10/20/2016	20161020-76	SHS A Sector A214 sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-77	SHS A Sector Hall fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-78	SHS A Sector Hall fountain (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-79	SHS Main Gym fountain (1)	0.0012	1.2
10/20/2016	20161020-80	SHS Athletic Trainer sink (1)	0.0014	1.4
10/20/2016	20161020-81	SHS Athletic Trainer sink (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-82	SHS D135 sink	0.0012	1.2
10/20/2016	20161020-83	SHS Boys Locker room fountain	ND @ 0.001	ND @ 1
10/20/2016	20161020-84	SHS Sector # (E141) hallway sink	ND @ 0.001	ND @ 1
10/20/2016	20161020-85	SHS Sector # #139 fountain	0.0010	1.0
10/20/2016	20161020-86	SHS Sector E #138 sink (1)	ND @ 0.001	ND @ 1

Silver Falls School District – Silverton High School

Lead Testing Results Summary 11/07/2016

Page 3 of 3

Date Collected	Lab #	Sample Site	Lead Test Results, mg/liter (or ppm) Action Level of 0.020	Lead Test Results, ppb Action Level of 20
10/20/2016	20161020-87	SHS Small gym entrance fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-88	SHS Small gym entrance fountain (2)	ND @ 0.001	ND @ 1
10/20/2016	20161020-89	SHS hall fountain outside Athletic Office	ND @ 0.001	ND @ 1
10/20/2016	20161020-90	SHS Weight Rm fountain (1)	ND @ 0.001	ND @ 1
10/20/2016	20161020-91	SHS Weight Rm fountain (2)	ND @ 0.001	ND @ 1